

Rangeview Metropolitan District - 2024 Drinking Water Quality Report

Covering Data for Calendar Year 2023

Public Water System ID: CO0103666

Esta es información importante. Si no la pueden leer, necesitan que alguien se la traduzca.

We are pleased to present to you this year's water quality report. Our constant goal is to provide you with a safe and dependable supply of drinking water. Please contact SCOTT E LEHMAN at 303-292-3456 (ext. 1003) with any questions or for public participation opportunities that may affect water quality.

General Information

All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline (1-800-426-4791) or by visiting epa.gov/ground-water-and-drinking-water.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immunocompromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV-AIDS or other immune system disorders, some elderly, and infants can be particularly at risk of infections. These people should seek advice about drinking water from their health care providers. For more information about contaminants and potential health effects, or to receive a copy of the U.S. Environmental Protection Agency (EPA) and the U.S. Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and microbiological contaminants call the EPA Safe Drinking Water Hotline at (1-800-426-4791).

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity. Contaminants that may be present in source water include:

- Microbial contaminants:** viruses and bacteria that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- Inorganic contaminants:** salts and metals, which can be naturally occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- Pesticides and herbicides:** may come from a variety of sources, such as agriculture, urban storm water runoff, and residential uses.
- Radioactive contaminants:** can be naturally occurring or be the result of oil and gas production and mining activities.
- Organic chemical contaminants:** including synthetic and volatile organic chemicals, which are byproducts of industrial processes and petroleum production, and also may come from gas stations, urban storm water runoff, and septic systems.

In order to ensure that tap water is safe to drink, the Colorado Department of Public Health and Environment prescribes regulations limiting the amount of certain contaminants in water provided by public water systems. The Food and Drug Administration regulations establish limits for contaminants in bottled water that must provide the same protection for public health.

Lead in Drinking Water

Lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. We are responsible for providing high quality drinking water and removing lead pipes, but cannot control the variety of materials used in plumbing components in your home. You share the responsibility for protecting yourself and your family from the lead in your home plumbing. You can take responsibility by identifying and removing lead materials within your home plumbing and taking steps to reduce your family's risk. Before drinking tap water, flush your pipes for several minutes by running your tap, taking a shower, doing laundry or a load of dishes. You can also use a filter certified by an American National Standards Institute accredited certifier to reduce lead in drinking water. If you are concerned about lead in your water and wish to have your water tested, contact SCOTT E LEHMAN at 303-292-3456. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available at epa.gov/safewater/lead. or at epa.gov/safewater/lead.

Source Water Assessment and Protection (SWAP)

Although a Source Water Assessment and Protections (SWAP) Report was not prepared by the Colorado Department of Public Health and Environment specifically for Rangeview Metropolitan District, SWAP reports for similar groundwater-based water systems provide a screening-level evaluation of potential contamination that **could** occur. It **does not** mean that contamination **has or will** occur. We use this information to evaluate the need to improve our current water treatment capabilities and to better

prepare for potential future contamination threats. This helps us to ensure that quality finished water is delivered to our customers. In addition, source water assessments assist us with developing a source water protection plan. Potential sources of contamination in our source water area are listed on the next page.

Please contact us to learn more about what you can do to help protect your drinking water sources, any questions about the Drinking Water Quality Report, to learn more about our system, or to attend scheduled public meetings. We want you, our valued customers, to be informed about the services we provide and the quality water we deliver to you every day.

Our Water Sources

<u>Sources (Water Type - Source Type)</u>	<u>Potential Source(s) of Contamination</u>
<p>WELLS SR-A1, LA-2, A-1, A-2, A-4, A-5, A-7, A-14, LFH-11, A13 and A20 (Groundwater-Wells)</p> <p>PURCHASED FROM WISE – PWSID CO0103843 (Surface Water - Consecutive Connection prior to Entry Point to Distribution System)</p>	<p>Although there is no SWAP report for our system, potential sources of contamination include high- and low- density residential land uses, agricultural operations, accidents and maintenance on nearby roadways, vandalism, terrorism, oil and gas operations, pasture and hay crops, etc. Please contact SCOTT E. LEHMAN at 303-292-3456 with questions regarding potential sources of contamination</p>

Terms and Abbreviations

- **Maximum Contaminant Level (MCL)** – The highest level of a contaminant allowed in drinking water.
- **Treatment Technique (TT)** – A required process intended to reduce the level of a contaminant in drinking water.
- **Health-Based** – A violation of either a MCL or TT.
- **Non-Health-Based** – A violation that is not a MCL or TT.
- **Action Level (AL)** – The concentration of a contaminant which, if exceeded, triggers treatment and other regulatory requirements.
- **Maximum Residual Disinfectant Level (MRDL)** – The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.
- **Maximum Contaminant Level Goal (MCLG)** – The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
- **Maximum Residual Disinfectant Level Goal (MRDLG)** – The level of a drinking water disinfectant, below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
- **Violation (No Abbreviation)** – Failure to meet a Colorado Primary Drinking Water Regulation.
- **Formal Enforcement Action (No Abbreviation)** – Escalated action taken by the State (due to the risk to public health, or number or severity of violations) to bring a non-compliant water system back into compliance.
- **Variance and Exemptions (V/E)** – Department permission not to meet a MCL or treatment technique under certain conditions.
- **Gross Alpha (No Abbreviation)** – Gross alpha particle activity compliance value. It includes radium-226, but excludes radon 222, and uranium.
- **Picocuries per liter (pCi/L)** – Measure of the radioactivity in water.
- **Nephelometric Turbidity Unit (NTU)** – Measure of the clarity or cloudiness of water. Turbidity in excess of 5 NTU is just noticeable to the typical person.
- **Compliance Value (No Abbreviation)** – Single or calculated value used to determine if regulatory contaminant level (e.g. MCL) is met. Examples of calculated values are the 90th Percentile, Running Annual Average (RAA) and Locational Running Annual Average (LRAA).
- **Average (x-bar)** – Typical value.
- **Range (R)** – Lowest value to the highest value.
- **Sample Size (n)** – Number or count of values (i.e. number of water samples collected).
- **Parts per million = Milligrams per liter (ppm = mg/L)** – One part per million corresponds to one minute in two years or a single penny in \$10,000.
- **Parts per billion = Micrograms per liter (ppb = ug/L)** – One part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.
- **Not Applicable (N/A)** – Does not apply or not available.
- **Level 1 Assessment** – A study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.
- **Level 2 Assessment** – A very detailed study of the water system to identify potential problems and determine (if possible) why an E. coli MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.
- **Below Detection Level (BDL)** - Due to limitations of chemical analysis procedures, small concentrations cannot be precisely measured. These concentrations are said to be Below the Detection Level (BDL) or below the lower limit of detection.

Detected Contaminants

RANGEVIEW MD routinely monitors for contaminants in your drinking water according to Federal and State laws. The following table(s) show all detections found in the period of January 1 to December 31, 2023 unless otherwise noted. The State of Colorado requires us to monitor for certain contaminants less than once per year because the concentrations of these contaminants are not expected to vary significantly from year to year, or our system is not considered vulnerable to this type of contamination. Therefore, some of our data, though representative, may be more than one year old. Violations and Formal Enforcement Actions, if any, are reported in the next section of this report.

Note: Only detected contaminants sampled within the last 5 years appear in this report. If no tables appear in this section then no contaminants were detected in the last round of monitoring.

Disinfectants Sampled in the Distribution System						
TT Requirement: At least 95% of samples per period (month or quarter) must be at least 0.2 ppm OR If sample size is less than 40 no more than 1 sample is below 0.2 ppm Typical Sources: Water additive used to control microbes						
Disinfectant Name	Time Period	Results	Number of Samples Below Level	Sample Size	TT Violation	MRDL
Chlorine	December, 2023	Lowest period percentage of samples meeting TT requirement: 100%	0	2	No	4.0 ppm

Lead and Copper Sampled in the Distribution System								
(Note: Samples were also tested for lead but all results were below the Minimum Reporting Level of 0.001 mg/l)								
Contaminant Name	Time Period	90 th Percentile	Sample Size	Unit of Measure	90 th Percentile AL	Sample Sites Above AL	90 th Percentile AL Exceedance	Typical Sources
Copper	08/18/2023 to 09/13/2023	0.3	10	ppm	1.3	0	No	Corrosion of household plumbing systems; Erosion of natural deposits

Disinfection Byproducts Sampled in the Distribution System									
Name	Year	Average	Range Low – High	Sample Size	Unit of Measure	MCL	MCLG	MCL Violation	Typical Sources
Total Haloacetic Acids (HAA5)	2023	3.5	3.5 to 3.5	1	ppb	60	N/A	No	Byproduct of drinking water disinfection
Total Trihalo-methanes (TTHM)	2023	15.8	15.8 to 15.8	1	ppb	80	N/A	No	

Radionuclides Sampled at the Entry Point to the Distribution System									
Contaminant Name	Year	Average	Range Low – High	Sample Size	Unit of Measure	MCL	MCLG	MCL Violation	Typical Sources
Combined Radium	2023	1.9	1.9 to 1.9	4	pCi/L	5	0	No	

Inorganic Contaminants Sampled at the Entry Point to the Distribution System									
(Note: We also tested one sample for Nitrite-nitrogen with result of Below the Laboratory Minimum Reporting Level of 0.1 mg/l)									
Contaminant Name	Year	Average	Range Low – High	Sample Size	Unit of Measure	MCL	MCLG	MCL Violation	Typical Sources
Arsenic	2023	0.5	0 to 2	4	ppb	10	0	No	Erosion of natural deposits; runoff from orchards; runoff from glass and electronics production wastes
Barium	2023	0.05	0.05 to 0.06	4	ppm	2	2	No	Discharge of drilling wastes; discharge from

Inorganic Contaminants Sampled at the Entry Point to the Distribution System									
(Note: We also tested one sample for Nitrite-nitrogen with result of Below the Laboratory Minimum Reporting Level of 0.1 mg/l)									
Contaminant Name	Year	Average	Range Low – High	Sample Size	Unit of Measure	MCL	MCLG	MCL Violation	Typical Sources
									metal refineries; erosion of natural deposits
Chromium	2023	3	2 to 5	4	ppb	100	100	No	Discharge from steel and pulp mills; erosion of natural deposits
Fluoride	2023	1.79	1.43 to 2.33	4	ppm	4	4	No	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
Nitrate-nitrogen (Note: Nitrite-N was BDL)	2023	0.17	0 to 0.2	6	ppm	10	10	No	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits
Selenium	2023	1.0	0 to 3	4	ppb	50	50	No	Discharge from petroleum and metal refineries, erosion of natural deposits, discharge from mines

Fluoride: This is an alert about your drinking water and a cosmetic dental problem that might affect children under nine years of age. At low levels, fluoride can help prevent cavities, but children drinking water containing more than 2 parts per million (ppm) of fluoride may develop cosmetic discoloration of their permanent teeth (dental fluorosis). The drinking water provided by your community water system has a fluoride concentration above 2 parts per million (ppm), but below 4 parts per million (ppm). Dental fluorosis, in its moderate or severe forms, may result in a brown staining and/or pitting of the permanent teeth. This problem occurs only in developing teeth, before they erupt from the gums. Children under nine years of age should be provided with alternative sources of drinking water or water that has been treated to remove the fluoride to avoid the possibility of staining and pitting of their permanent teeth. You may also want to contact your dentist about proper use by young children of fluoride-containing products. Older children and adults may safely drink the water.

Drinking water containing more than 4 parts per million (ppm) of fluoride (the Colorado Department of Public Health and Environment’s drinking water standard) can increase your risk of developing bone disease. Your drinking water does not contain more than 4 parts per million (ppm) of fluoride, but we’re required to notify you when we discover that the fluoride levels in your drinking water exceed 2 parts per million (ppm) because of this cosmetic dental problem. For more information, please contact us. Some home water treatment units are also available to remove fluoride from drinking water. To learn more about available home water treatment units, you may call NSF International at (1-877-8-NSF-HELP).

Volatile Organic Contaminants Samples at the Entry Point to the Distribution System									
Name	Year	Average	Range Low – High	Sample Size	Unit of Measure	MCL	MCLG	MCL Violation	Typical Sources
Ethylbenzene	2023	2.14	0 to 15.3	8	ppb	700	700	No	Discharge from petroleum refineries and chemical factories, solvent from painting operations
Xylenes	2023	11.03	0 to 79.7	8	ppb	10,000	10,000	No	

Secondary Contaminants**						
**Secondary standards are <u>non-enforceable</u> guidelines for contaminants that may cause cosmetic effects (such as skin, or tooth discoloration) or aesthetic effects (such as taste, odor, or color) in drinking water.						
Contaminant Name	Year	Average	Range Low – High	Sample Size	Unit of Measure	Secondary Standard
Sodium	2023	94.28	72.8 to 136	4	ppm	N/A – monitor only

Violations, Significant Deficiencies, and Formal Enforcement Actions

Non-Health-Based Violations

These violations do not usually mean that there was a problem with the water quality. If there had been, we would have notified you immediately. We missed collecting a sample (water quality is unknown), we reported the sample result after the due date, or we did not complete a report/notice by the required date.

Name	Description	Time Period
VOLATILE ORGANICS	FAILURE TO MONITOR AND/OR REPORT	01/01/2023 ~ 03/31/2023
SYNTHETIC ORGANICS	FAILURE TO MONITOR AND/OR REPORT	01/01/2023 ~ 03/31/2023
NITRATE	FAILURE TO MONITOR AND/OR REPORT	01/01/2023 ~ 03/31/2023
INORGANICS GROUP	FAILURE TO MONITOR AND/OR REPORT	01/01/2023 ~ 03/31/2023
FLUORIDE	FAILURE TO MONITOR AND/OR REPORT	01/01/2023 ~ 03/31/2023
CHLORINE/CHLORAMINE	FAILURE TO MONITOR AND/OR REPORT	11/01/2023 ~ 11/30/2023
TOTAL COLIFORM	FAILURE TO MONITOR AND/OR REPORT	11/01/2023 ~ 11/30/2023

Additional Violation Information

Concerning the violations for the first quarter of 2023, for which sample results were to be reported by April 10th:

- On April 20th we followed up with Colorado Analytical Laboratory to verify that the analyses for our compliance samples collected on March 30th were in progress. We received the results from the lab on April 26th and the Water Quality Control Division (WQCD) of the Colorado Department of Public Health and Environment has acknowledged their receipt of the results.
- In the future, we will endeavor to collect samples in a more timely manner to allow for analysis and compliant data submittal to the WQCD.
- Public notice was distributed with our billings for May 2023 water service and also posted on our website <https://rangeviewmetro.org>.

Concerning the violation for November coliform and chlorine:

- We submitted samples for December Coliform P/A on 12/6/23 and those results have come back Absent.
- Rangeview has put additional procedures in place to verify samples were submitted and analyzed for each monitoring period. This is to avoid this situation from reoccurring again in the future.

There was no need for you, as a consumer of our water, to take any actions or to use an alternate water supply due to these Non-Health-Based Violations.

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

Contact Information: Rangeview Metropolitan District, 34501 East Quincy Ave., Bldg. 65, Ste. A, Watkins CO 80137
Attn: Scott Lehman (303)292-3456 Ext. 1003

There were no Significant Deficiencies (requiring public notification), or Formal Enforcement Actions